

George Latimer **County Executive**

Sherlita Amler, M.D. Commissioner of Health

December 17, 2021

Town of Lewisboro 11 Main Street, PO Box 500 South Salem, NY 10590

Attn: The Hon. Peter Parsons, Supervisor

Re: 2022 Certificate to Operate

Community Water Supply Oakridge Water Company

Dear Supervisor Parsons:

Receipt of your fees for the above-referenced public or private water system is hereby acknowledged. Please be advised that our records reveal that your water supply is being operated in compliance with applicable State and County Laws and Regulations.

Enclosed is your annual Permit to Operate a Community Water Supply, which is valid until December 31, 2022.

Very truly yours,

Delroy Taylor, P.E. **Assistant Commissioner**

Bureau of Environmental Quality

DT:pm

Enclosure

cc: File



Westchester County Department of Health

George Latimer County Executive Department of Health Sherlita Amler, M.D. Commissioner of Health

Bureau of Environmental Quality

Permit to Operate A Public Water Supply

Facility Name:	OAKRIDGE WATER DISTRICT	WCDH Facility 00059 Number:
Owner:	TOWN OF LEWISBORO	Equility Type:

State: NY

Attention: THE HONORABLE PETER PARSONS, SUPERVISOR

Mailing Address: - PO BOX 500

Municipality: SOUTH SALEM Water Supply Description:

An unfiltered groundwater supply consisting of five (5) wells with a total producton capacity of 282,000 gpd, an average daily consumption of 55,000 gallons, a water distribution storage capacity of 95,000 gallons, and with treatment that includes permanganate and green sand filtration and liquid chlorine disinfection, serving a population of 892.

This Permit supersedes any earlier Permit to Operate issued for this supply by the Department.

That the operation of this supply shall be in accordance with the supply description, approved plans, and any special conditions for this supply on file with the Department.

This public water supply shall be operated in compliance with the Provisions of Chapter 873, Article VII of the Laws of Westchester County and Part 5 of the New York State Sanitary Code.

This Permit shall be suspended or revoked as provided by the Laws of Westchester County, if this public water supply is maintained or operated other than in compliance with the above.

FOR THE COMMISSIONER

By:

SHERLITA AMLER, M.D.

By:

Sherlita Amler, M.D. Commissioner of Health

Permit Issued:

to Umles MD

Permit Expires:

12/31/2022

01/01/2022

NYS Facility

No.:

Zip Code: 10590

5918395

Delroy Taylor, P.E., Assistant Commissioner Bureau of Environmental Quality