

George Latimer County Executive

Sherlita Amler, M.D. Commissioner of Health

Oakridge Water Company
Town of Lewisboro
11 Main Street
South Salem, NY 10590
Attn: Hon. Peter Parsons, Supervisor

February 8, 2021

RE: Reduced Monitoring - Lead and Copper

Oakridge Water System PWS ID#: NY5918395 Lewisboro (T)

Dear Mr. Parsons:

This Department is in receipt of consecutive satisfactory annual Lead and Copper monitoring results, collected between January 01, 2018 and September 30, 2020 for the above referenced Public Water Supply (PWS). Based on these results, Oakridge PWS has been placed on an every three (3) years Lead and Copper monitoring schedule effective January 01, 2021, in accordance with Part 5, Subpart 5-1, Section 5-1.42 of the New York State Sanitary Code.

In light of the above, Oakridge PWS (population 892) shall conduct Lead and Copper monitoring at a reduced frequency of:

• Ten (10) samples, collected every three (3) years between June 1 and September 30 each year starting with a 2021 monitoring period.

The water samples for Lead and Copper monitoring must be collected from the reduced sampling sites indicated on the PWS' approved Comprehensive Monitoring Plan. Any deviation from the approved monitoring plan must receive approval from this Department before sampling is performed.

Additionally, these sample results must be submitted by the Designated Operator in Responsible Charge to the Department with a report indicating the 90th percentile levels for lead and copper for the specified monitoring period, by the 10th calendar day of October of the sampling year.

Please see the enclosed Sample Schedule highlighting this change in monitoring frequency.

Should you have any questions, please contact Chika Amasiani, Assistant Engineer at (914) 864-7338 or the undersigned at (914) 864-7348.

Telephone: (914) 813-5000

Very truly yours,

Zaw Thein, P.E. Associate Engineer

Bureau of Environmental Quality

Fax: (914) 813-4691

ZT:CA enclosure

cc: Michael McLaughlin, Water System Operator, VRI, Inc. Phil Derrenbacher, Water System Operator, VRI, Inc.

REDUCE RECYCLE

Andy Tse, NYSDOH File